

# OCM BOCES - Water Testing for Lead

**DOH Action Limit = 15 ppb**

*date last updated: June 15, 2021*

School Name: **Alternative High School at Henry (STARS)**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2106529 - 001A	S - 1	5/6/2021	Rm 119	Kitchen sink	<0.0010	<1.0	5/24/2021	OK	
2106529 - 002A	S - 2	5/6/2021	by Rm 119	Water cooler	<0.0010	<1.0	5/24/2021	OK	
2106529 - 003A	S - 3	5/6/2021	by Rm 120	Bathroom faucet	0.0012	1.2	5/24/2021	OK	
2106529 - 004A	S - 4	5/6/2021	Art Rm	Left classroom faucet	0.0027	2.7	5/24/2021	OK	
2106529 - 005A	S - 5	5/6/2021	Art Rm	Right classroom faucet	0.0016	1.6	5/24/2021	OK	
2106529 - 006A	S - 6	5/6/2021	by Rm 143	Bathroom faucet	<0.0010	<1.0	5/24/2021	OK	
2106529 - 007A	S - 7	5/6/2021	by Rm 143	Bathroom faucet	<0.0010	<1.0	5/24/2021	OK	
2106529 - 008A	S - 8	5/6/2021	by Rm 143	Bathroom faucet	<0.0010	<1.0	5/24/2021	OK	
2106529 - 009A	S - 9	5/6/2021	by Rm 143	Water cooler	<0.0010	<1.0	5/24/2021	OK	
2106529 - 010A	S - 10	5/6/2021	Rm 143	Kitchen faucet	<0.0010	<1.0	5/24/2021	OK	
2106529 - 011A	S - 11	5/6/2021	Rm 117	Right bathroom faucet	<0.0010	<1.0	5/24/2021	OK	
2106529 - 012A	S - 12	5/6/2021	Rm 117	Left bathroom faucet	0.0018	1.8	5/24/2021	OK	
2106529 - 013A	S - 13	5/6/2021	Rm 116	Left bathroom faucet	<0.0010	<1.0	5/24/2021	OK	
2106529 - 014A	S - 14	5/6/2021	by Rm 115	Water cooler	<0.0010	<1.0	5/24/2021	OK	
2106529 - 015A	S - 15	5/6/2021	Rm 105	Bathroom faucet	0.0014	1.4	5/24/2021	OK	