

OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

date last updated: July 15, 2021

School Name: **Alternative to Homebound (Zogg)**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2107386 - 001A	Zogg-01 CF	5/19/2021	Rm 120	Classroom faucet	0.0034	3.4	6/15/2021	OK	
2107386 - 002A	Zogg-02 CF	5/19/2021	Rm 122	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107386 - 003A	Zogg-03 CF	5/19/2021	Rm 119	Classroom faucet	0.0500 *	50 *	6/15/2021	No	signage/retest
2107386 - 004A	Zogg-04 BF	5/19/2021	Rm 126	Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107386 - 005A	Zogg-05 CF	5/19/2021	Rm 118	Right Classroom faucet	0.0068	6.8	6/15/2021	OK	
2107386 - 006A	Zogg-06 KF	5/19/2021	Rm 118	Left Kitchen faucet	0.0260 *	26 *	6/15/2021	No	signage/retest
2107386 - 007A	Zogg-07 CF	5/19/2021	Rm 127	Classroom faucet	0.0039	3.9	6/15/2021	OK	
2107386 - 008A	Zogg-08 CF	5/19/2021	Rm 128	Classroom faucet	0.0021	2.1	6/15/2021	OK	
2107386 - 009A	Zogg-09 BF	5/19/2021	Rm 130	Bathroom faucet	0.0056	5.6	6/15/2021	OK	
2107386 - 010A	Zogg-010 BF	5/19/2021	Rm 116	Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107386 - 011A	Zogg-011 BF	5/19/2021	Rm 115	Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	

RESAMPLE

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2109432 - 004A	Zogg-06 KF	6/18/2021	Rm 118	Left Kitchen faucet	0.0051	5.1	7/14/2021	OK	no action
2109432 - 005A	Zogg-03 CF	6/18/2021	Rm 119	Classroom faucet	0.046*	46.0*	7/14/2021	No	signage & replace