

OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

date last updated: July 15, 2021

School Name: **Cortlandville Campus (McEvoy)**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * (parts per billion)	Lab Report Receipt Date	Current Status	Action Taken
2107485 - 001 A	MC01	5/20/2021	Men's bathroom 2nd floor	Bathroom faucet	0.023 *	23.0 *	6/15/2021	No	signage/retest
2107485 - 002 A	MC02	5/20/2021	Women's bathroom 2nd floor	Bathroom faucet	0.014	1.4	6/15/2021	OK	
2107485 - 003 A	MC03	5/20/2021	Rm E201	Classroom faucet	0.0053	5.3	6/15/2021	OK	
2107485 - 004 A	MC04	5/20/2021	Rm E202	Classroom faucet	0.0018	1.8	6/15/2021	OK	
2107485 - 005 A	MC05	5/20/2021	Rm E107	Classroom faucet	0.0064	6.4	6/15/2021	OK	
2107485 - 006 A	MC06	5/20/2021	outside E102/3	Bathroom faucet	0.011	11.0	6/15/2021	OK	
2107485 - 007 A	MC07	5/20/2021	Rm E102/3	Water Cooler	<0.0010	<1.0	6/15/2021	OK	
2107485 - 008 A	MC08	5/20/2021	Rm E110	Classroom faucet	0.0023	2.3	6/15/2021	OK	
2107485 - 009 A	MC09	5/20/2021	Classroom "C"	Classroom faucet	0.0036	3.6	6/15/2021	OK	
2107485 - 010 A	MC10	5/20/2021	Women's bathroom by stage B109	Left Bathroom faucet	0.0041	4.1	6/15/2021	OK	
2107485 - 011 A	MC11	5/20/2021	Women's bathroom by stage B109	Right Bathroom faucet	0.0049	4.9	6/15/2021	OK	
2107485 - 012 A	MC12	5/20/2021	hallway behind stage B109	Water Cooler	<0.0010	<1.0	6/15/2021	OK	
2107485 - 013 A	MC13	5/20/2021	Men's bathroom by stage B109	Left Bathroom faucet	0.0065	6.5	6/15/2021	OK	
2107485 - 014 A	MC14	5/20/2021	Men's bathroom by stage B109	Right Bathroom faucet	0.0074	7.4	6/15/2021	OK	
2107485 - 015 A	MC15	5/20/2021	Rm C114	Classroom faucet	0.0021	2.1	6/15/2021	OK	
2107485 - 016 A	MC16	5/20/2021	Kitchen Serv. Rm C106	Kitchen faucet	0.0019	1.9	6/15/2021	OK	
2107485 - 017 A	MC17	5/20/2021	Kitchen Rm C106	Kitchen faucet	0.0025	2.5	6/15/2021	OK	
2107485 - 018 A	MC18	5/20/2021	Kitchen Rm C106	Ice	<0.0010	<1.0	6/15/2021	OK	
2107485 - 019 A	MC19	5/20/2021	Kitchen Rm C106	Kitchen faucet	0.0033	3.3	6/15/2021	OK	
2107485 - 020 A	MC20	5/20/2021	Kitchen Rm C106	Kitchen faucet	0.0032	3.2	6/15/2021	OK	
2107485 - 021 A	MC21	5/20/2021	Commons rm B100	Bathroom faucet	0.0025	2.5	6/15/2021	OK	
2107485 - 022 A	MC22	5/20/2021	Commons rm B100	Bathroom faucet	0.0010	1.0	6/15/2021	OK	
2107485 - 023 A	MC23	5/20/2021	Nurse rm B101	Nurse sink	0.0052	5.2	6/15/2021	OK	
2107485 - 024 A	MC24	5/20/2021	Nurse rm B101	Water Cooler	<0.0010	<1.0	6/15/2021	OK	
2107485 - 025 A	MC25	5/20/2021	outside rm 104	Water Cooler	<0.0010	<1.0	6/15/2021	OK	
2107485 - 026 A	MC26	5/20/2021	Storage rm C105	Classroom faucet	0.0064	6.4	6/15/2021	OK	
2107485 - 027 A	MC27	5/20/2021	Rm C104	Classroom faucet	0.0053	5.3	6/15/2021	OK	
2107485 - 028 A	MC28	5/20/2021	outside rm A109	Kitchen faucet	0.0022	2.2	6/15/2021	OK	
2107485 - 029 A	MC29	5/20/2021	Bathroom by rm A109	Right Bathroom faucet	0.0037	3.7	6/15/2021	OK	
2107485 - 030 A	MC30	5/20/2021	Bathroom by rm A109	Left Bathroom faucet	0.0038	3.8	6/15/2021	OK	
2107485 - 031 A	MC31	5/20/2021	Rm A112 Art	Classroom faucet	0.0042	4.2	6/15/2021	OK	
2107485 - 032 A	MC32	5/20/2021	Rm A110	Classroom faucet	0.0054	5.4	6/15/2021	OK	
2107485 - 033 A	MC33	5/20/2021	Rm A108	Classroom faucet	0.0080	8.0	6/15/2021	OK	
2107485 - 036 A	MC36	5/20/2021	Bathroom by rm A103	Bathroom faucet	0.0057	5.7	6/15/2021	OK	
2107485 - 037 A	MC37	5/20/2021	Rm A102	Classroom faucet	0.0053	5.3	6/15/2021	OK	
2107485 - 038 A	MC38	5/20/2021	Kitchen by rm A103	Kitchen faucet	0.0025	2.5	6/15/2021	OK	
2107485 - 039 A	MC39	5/20/2021	Rm A103	Classroom faucet	0.0067	6.7	6/15/2021	OK	
2107485 - 040 A	MC40	5/20/2021	Bathroom by rm A103	Bathroom faucet	0.0096	9.6	6/15/2021	OK	
2107485 - 041 A	MC41	5/20/2021	Bathroom by rm A101	Bathroom faucet	0.0025	2.5	6/15/2021	OK	

OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

date last updated: July 15, 2021

School Name: **Cortlandville Campus (McEvoy)**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * (parts per billion)	Lab Report Receipt Date	Current Status	Action Taken
2107485 - 042 A	MC42	5/20/2021	Rm A101	Classroom faucet	0.0067	6.7	6/15/2021	OK	
2107485 - 043 A	MC43	5/20/2021	Women's bathroom by rm A207A	Bathroom faucet	0.0036	3.6	6/15/2021	OK	
2107485 - 044 A	MC44	5/20/2021	Men's bathroom by rm A207A	Bathroom faucet	0.0057	5.7	6/15/2021	OK	
2107485 - 045 A	MC45	5/20/2021	Bathroom by rm A204A	Bathroom faucet	0.0027	2.7	6/15/2021	OK	
2107485 - 046 A	MC46	5/20/2021	Bathroom by rm A204A	Bathroom faucet	0.0048	4.8	6/15/2021	OK	
2107485 - 047 A	MC47	5/20/2021	by rm A217	Water Cooler	<0.0010	<1.0	6/15/2021	OK	
2107485 - 048 A	MC48	5/20/2021	Bathroom outside nurse rm A223	Bathroom faucet	0.0028	2.8	6/15/2021	OK	
2107485 - 049 A	MC49	5/20/2021	Bathroom outside nurse rm A223	Bathroom faucet	0.0088	8.8	6/15/2021	OK	
2107485 - 050 A	MC50	5/20/2021	Rm D202	Kitchen faucet	0.0097	9.7	6/15/2021	OK	
2107485 - 051 A	MC51	5/20/2021	Rm D202 bathroom	Bathroom faucet	0.012	12.0	6/15/2021	OK	
2107485 - 052 A	MC52	5/20/2021	Rm D204	Kitchen faucet	0.0019	1.9	6/15/2021	OK	
2107485 - 053 A	MC53	5/20/2021	Rm D204	Classroom faucet	0.0060	6.0	6/15/2021	OK	
2107485 - 054 A	MC54	5/20/2021	Rm D204 bathroom	Bathroom faucet	0.0081	8.1	6/15/2021	OK	
2107485 - 055 A	MC55	5/20/2021	Rm D200 Women's bathroom	Bathroom faucet	0.0056	5.6	6/15/2021	OK	
2107485 - 056 A	MC56	5/20/2021	Rm D200 Men's bathroom	Bathroom faucet	0.0036	3.6	6/15/2021	OK	
2107485 - 057 A	MC57	5/20/2021	Rm D200 Men's bathroom	Right Bathroom faucet	0.0079	7.9	6/15/2021	OK	
2107485 - 058 A	MC58	5/20/2021	Rm D205	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107485 - 059 A	MC59	5/20/2021	Rm D205	Classroom faucet	0.0012	1.2	6/15/2021	OK	
2107485 - 060 A	MC60	5/20/2021	Rm D205	Left Classroom faucet	0.0064	6.4	6/15/2021	OK	
2107485 - 061 A	MC61	5/20/2021	Rm D206	Kitchen faucet	0.0049	4.9	6/15/2021	OK	
2107485 - 062 A	MC62	5/20/2021	Rm D206 1	Classroom faucet	0.0036	3.6	6/15/2021	OK	
2107485 - 063 A	MC63	5/20/2021	Rm D206 2	Classroom faucet	0.0011	1.1	6/15/2021	OK	
2107485 - 064 A	MC64	5/20/2021	Rm D206 bathroom	Bathroom faucet	0.0026	2.6	6/15/2021	OK	
2107485 - 065 A	MC65	5/20/2021	Conference rm Women's bathroom	Bathroom faucet	0.080 *	80.0 *	6/15/2021	No	signage/retest
2107485 - 066 A	MC66	5/20/2021	Conference rm Men's bathroom	Bathroom faucet	0.014	14.0	6/15/2021	OK	
2107485 - 067 A	MC67	5/20/2021	Conference rm Kitchen sink	Kitchen faucet	0.011	11.0	6/15/2021	OK	

RESAMPLE

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * (parts per billion)	Lab Report Receipt Date	Current Status	Action Taken
2109432 - 002 A	MC02	5/20/2021	Conference rm Women's bathroom	Bathroom faucet	0.017*	17.0*	7/14/2021	No	signage & replace
2109432 - 003 A	MC03	6/18/2021	Men's bathroom 2nd floor	Bathroom faucet	0.01	10.0	7/14/2021	ok	no action