

# OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

*date last updated: June 15, 2021*

School Name: **Henry CTE**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2106667 - 001A	CTE-1	5/7/2021	Rm 121	Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 002A	CTE-2	5/7/2021	Rm 121	Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 003A	CTE-3	5/7/2021	Rm 120	Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 004A	CTE-4	5/7/2021	Rm 120	Bathroom faucet	0.0014	1.4	6/10/2021	OK	
2106667 - 005A	CTE-5	5/7/2021	Rm 117	Left Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 006A	CTE-6	5/7/2021	Rm 117	Right Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 007A	CTE-7	5/7/2021	Rm 116	Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 008A	CTE-8	5/7/2021	Rm 115	Left Classroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 009A	CTE-9	5/7/2021	Rm 115	Right Classroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 010A	CTE-10	5/7/2021	Rm 115	Bathroom faucet	0.0037	3.7	6/10/2021	OK	
2106667 - 011A	CTE-11	5/7/2021	Rm 122	Left Kitchen faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 012A	CTE-12	5/7/2021	Rm 122	Center Kitchen faucet	0.0011	1.1	6/10/2021	OK	
2106667 - 013A	CTE-13	5/7/2021	Rm 122	Right Kitchen faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 014A	CTE-14	5/7/2021	Rm 114	Right Classroom faucet	0.0031	3.1	6/10/2021	OK	
2106667 - 015A	CTE-15	5/7/2021	Rm 114	Center Classroom faucet	0.0023	2.3	6/10/2021	OK	
2106667 - 016A	CTE-16	5/7/2021	Rm 114	Left Classroom faucet	0.0089	8.9	6/10/2021	OK	
2106667 - 017A	CTE-17	5/7/2021	Rm 114	Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 018A	CTE-18	5/7/2021	by Rm 114	Water cooler	<0.0010	<1.0	6/10/2021	OK	
2106667 - 019A	CTE-19	5/7/2021	by Rm 114	Bathroom faucet	0.0015	1.5	6/10/2021	OK	
2106667 - 020A	CTE-20	5/7/2021	by Rm 114	Bathroom faucet	0.0017	1.7	6/10/2021	OK	
2106667 - 021A	CTE-21	5/7/2021	Rm 130	Classroom faucet	0.0064	6.4	6/10/2021	OK	
2106667 - 022A	CTE-22	5/7/2021	Rm 132	Classroom faucet	0.0016	1.6	6/10/2021	OK	
2106667 - 023A	CTE-23	5/7/2021	by Rm 131	Water cooler	<0.0010	<1.0	6/10/2021	OK	
2106667 - 024A	CTE-24	5/7/2021	Rm 131	Classroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 025A	CTE-25	5/7/2021	Rm 133	Classroom faucet	0.0039	3.9	6/10/2021	OK	
2106667 - 026A	CTE-26	5/7/2021	Rm 133	Bathroom faucet	0.0038	3.8	6/10/2021	OK	
2106667 - 027A	CTE-27	5/7/2021	Rm 134	Bathroom faucet	0.0062	6.2	6/10/2021	OK	
2106667 - 028A	CTE-28	5/7/2021	Rm 214	Left Bathroom faucet	0.0025	2.5	6/10/2021	OK	
2106667 - 029A	CTE-29	5/7/2021	Rm 214	Right Bathroom faucet	0.0028	2.8	6/10/2021	OK	
2106667 - 030A	CTE-30	5/7/2021	Rm 214	Left Bathroom faucet	0.0150	15.0	6/10/2021	OK	
2106667 - 031A	CTE-31	5/7/2021	Rm 214	Right Bathroom faucet	0.0100	10.0	6/10/2021	OK	
2106667 - 032A	CTE-32	5/7/2021	Rm 135	Bathroom faucet	0.0033	3.3	6/10/2021	OK	
2106667 - 033A	CTE-33	5/7/2021	Rm 135	Classroom faucet	0.0050	5.0	6/10/2021	OK	
2106667 - 034A	CTE-34	5/7/2021	Rm 138A	Left Kitchen faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 036A	CTE-36	5/7/2021	Rm 112A	Ice Room	<0.0010	<1.0	6/10/2021	OK	
2106667 - 038A	CTE-38	5/7/2021	Rm 112A	Center Kitchen faucet	0.0036	3.6	6/10/2021	OK	
2106667 - 039A	CTE-39	5/7/2021	Rm 112A	Left Kitchen faucet	0.0024	2.4	6/10/2021	OK	
2106667 - 040A	CTE-40	5/7/2021	Rm 112	Kitchen faucet	0.0034	3.4	6/10/2021	OK	

# OCM BOCES - Water Testing for Lead

**DOH Action Limit = 15 ppb**

*date last updated: June 15, 2021*

School Name: **Henry CTE**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2106667 - 041A	CTE-41	5/7/2021	Rm 110	Right Kitchen faucet	0.0031	3.1	6/10/2021	OK	
2106667 - 042A	CTE-42	5/7/2021	Rm 110	Center Kitchen faucet	0.0032	3.2	6/10/2021	OK	
2106667 - 044A	CTE-44	5/7/2021	Rm 140	Kitchen faucet	0.0025	2.5	6/10/2021	OK	
2106667 - 045A	CTE-45	5/7/2021	Rm 140	Bathroom faucet	0.0019	1.9	6/10/2021	OK	
2106667 - 046A	CTE-46	5/7/2021	hall by rm 106 storeroom	Water cooler	<0.0010	<1.0	6/10/2021	OK	
2106667 - 047A	CTE-47	5/7/2021	Women's Rm by rm 152	Bathroom faucet	0.0024	2.4	6/10/2021	OK	
2106667 - 048A	CTE-48	5/7/2021	Rm 105	Kitchen faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 049A	CTE-49	5/7/2021	Rm 105	Left Classroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 050A	CTE-50	5/7/2021	Rm 105	Right Classroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 051A	CTE-51	5/7/2021	Men's Rm by rm 152	Bathroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 052A	CTE-52	5/7/2021	Rm 153	Left Classroom faucet	<0.0010	<1.0	6/10/2021	OK	
2106667 - 053A	CTE-53	5/7/2021	Rm 153	Right Classroom faucet	0.0110	11.0	6/10/2021	OK	
2106667 - 054A	CTE-54	5/7/2021	Rm 153	Bathroom faucet	0.0016	1.6	6/10/2021	OK	
2106667 - 055A	CTE-55	5/7/2021	ACH BR rm 156	Bathroom faucet	0.0011	1.1	6/10/2021	OK	
2106667 - 056A	CTE-56	5/7/2021	Women's bathroom 153A	Bathroom faucet	0.0020	2.0	6/10/2021	OK	
2106667 - 057A	CTE-57	5/7/2021	Men's bathroom 153B	Bathroom faucet	0.0021	2.1	6/10/2021	OK	