

# OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

*date last updated: June 15, 2021*

School Name: **Innovation Tech (7-8- RODAX)**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2106948 - 001A	IT01 L BF	5/12/2021	A118	Left Bathroom faucet	0.0076	7.6	6/4/2021	OK	
2106948 - 002A	IT02 R BF	5/12/2021	A118	Right Bathroom faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 003A	IT03 BF	5/12/2021	A119	Bathroom faucet	0.0012	1.2	6/4/2021	OK	
2106948 - 004A	IT04 BF	5/12/2021	A120	Bathroom faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 005A	IT05 CF	5/12/2021	A15	Classroom faucet	0.0018	1.8	6/4/2021	OK	
2106948 - 006A	IT06 WC	5/12/2021	A110 Hall	Water Cooler	<0.0010	<1.0	6/4/2021	OK	
2106948 - 007A	IT07 KF	5/12/2021	A110 Hall	Kitchen faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 008A	IT08 KF	5/12/2021	A112	Kitchen faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 009A	IT09 BF	5/12/2021	A108	Bathroom faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 010A	IT10 BF	5/12/2021	A108	Bathroom faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 011A	IT11 BF	5/12/2021	A113	Bathroom faucet	0.0011	1.1	6/4/2021	OK	
2106948 - 012A	IT12 BF	5/12/2021	A112	Bathroom faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 013A	IT13 KF	5/12/2021	Conference Rm	Kitchen faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 014A	IT14 BF	5/12/2021	Conference Rm	Bathroom faucet	<0.0010	<1.0	6/4/2021	OK	
2106948 - 015A	IT15 BF	5/12/2021	Conference Rm	Bathroom faucet	<0.0010	<1.0	6/4/2021	OK	