

OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

date last updated: June 18, 2021

School Name: **Seven Valleys New Tech. Cortland**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2107484 - 001 A	7V01	5/20/2021	Cafeteria	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107484 - 002 A	7V02	5/20/2021	Kitchen	Kitchen faucet	0.0052	5.2	6/15/2021	OK	
2107484 - 003 A	7V03	5/20/2021	Kitchen	Left Kitchen faucet	0.0016	1.6	6/15/2021	OK	
2107484 - 004 A	7V04	5/20/2021	Kitchen	Right Kitchen faucet	0.0032	3.2	6/15/2021	OK	
2107484 - 005 A	7V05	5/20/2021	by rm 104	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107484 - 006 A	7V06	5/20/2021	rm 129	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107484 - 007 A	7V07	5/20/2021	Men's bathroom by rm 129	Left Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107484 - 008 A	7V08	5/20/2021	Men's bathroom by rm 129	Center Bathroom faucet	0.0012	1.2	6/15/2021	OK	
2107484 - 009 A	7V09	5/20/2021	Men's bathroom by rm 129	Right Bathroom faucet	0.0010	1.0	6/15/2021	OK	
2107484 - 010 A	7V10	5/20/2021	Women's bathroom by rm 123	Left Bathroom faucet	0.0011	1.1	6/15/2021	OK	
2107484 - 011 A	7V11	5/20/2021	Women's bathroom by rm 123	Center Left Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107484 - 012 A	7V12	5/20/2021	Women's bathroom by rm 123	Center Right Bathroom faucet	0.0028	2.8	6/15/2021	OK	
2107484 - 013 A	7V13	5/20/2021	Women's bathroom by rm 123	Right Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107484 - 014 A	7V14	5/20/2021	bathroom rm 106	Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	