

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2107483 - 001 A	CAS01	5/20/2021	Cafeteria	Kitchen faucet	0.0017	1.7	6/15/2021	OK	
2107483 - 002 A	CAS02	5/20/2021	Women's bathroom rm 120	Left Bathroom faucet	0.011	11.0	6/15/2021	OK	
2107483 - 003 A	CAS03	5/20/2021	Women's bathroom rm 120	Right Bathroom faucet	0.0054	5.4	6/15/2021	OK	
2107483 - 004 A	CAS04	5/20/2021	Men's bathroom rm 122	Left Bathroom faucet	0.0028	2.8	6/15/2021	OK	
2107483 - 005 A	CAS05	5/20/2021	Men's bathroom rm 122	Right Bathroom faucet	0.0098	9.8	6/15/2021	OK	
2107483 - 006 A	CAS06	5/20/2021	by Men's bathroom rm 122	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107483 - 007 A	CAS07	5/20/2021	rm 123	Classroom faucet	0.0056	5.6	6/15/2021	OK	
2107483 - 008 A	CAS08	5/20/2021	Men's bathroom rm 153	Right Bathroom faucet	0.0033	3.3	6/15/2021	OK	
2107483 - 009 A	CAS09	5/20/2021	Men's bathroom rm 153	Center Bathroom faucet	0.0038	3.8	6/15/2021	OK	
2107483 - 010 A	CAS10	5/20/2021	Men's bathroom rm 153	Left Bathroom faucet	0.025 *	25.0 *	6/15/2021	No	signage/retest
2107483 - 011 A	CAS11	5/20/2021	Women's bathroom rm 151	Right Bathroom faucet	0.0056	5.6	6/15/2021	OK	
2107483 - 012 A	CAS12	5/20/2021	Women's bathroom rm 151	Center Right Bathroom faucet	0.0043	4.3	6/15/2021	OK	
2107483 - 013 A	CAS13	5/20/2021	Women's bathroom rm 151	Center Left Bathroom faucet	0.0087	8.7	6/15/2021	OK	
2107483 - 014 A	CAS14	5/20/2021	Women's bathroom rm 151	Left Bathroom faucet	0.0027	2.7	6/15/2021	OK	
2107483 - 015 A	CAS15	5/20/2021	rm 146	Classroom faucet	0.0032	3.2	6/15/2021	OK	
2107483 - 016 A	CAS16	5/20/2021	Nurse's office rm 136	Nurse's sink	0.0022	2.2	6/15/2021	OK	

RESAMPLE:

Re-Samples Collected on 06/18/2021				
Sample #	Function/Space	Room #	Fixture Type	Sample Results
2109432-001A	Men's Bathroom	153	Left bathroom faucet	7.8 ppb