

OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

date last updated: June 17, 2021

School Name: **Crown Road Campus**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2107235 - 001A	CR1 WC	5/18/2021	Hallway by rm 8	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 002A	CR2 WC	5/18/2021	Rm 9	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 003A	CR3 R BF WB	5/18/2021	Women's bathroom by rm 9	Right Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 004A	CR4 L BF MB	5/18/2021	Men's bathroom by rm 11	Left Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 005A	CR5 R BF MB	5/18/2021	Men's bathroom by rm 11	Right Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 006A	CR6 CF 22	5/18/2021	Rm 22	Classroom faucet	0.0012	1.2	6/15/2021	OK	
2107235 - 007A	CR7 KF Kitchen	5/18/2021	Kitchen	Kitchen faucet	0.0012	1.2	6/15/2021	OK	
2107235 - 008A	CR8 KF 23 CAF	5/18/2021	Cafeteria	Kitchen faucet	0.0010	1.0	6/15/2021	OK	
2107235 - 009A	CR9 KF Kitchen	5/18/2021	Kitchen	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 010A	CR10 KF Kithcen	5/18/2021	Kitchen	Kitchen faucet	0.0010	1.0	6/15/2021	OK	
2107235 - 011A	CR11 KF Kitchen	5/18/2021	Kitchen	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 012A	CR12 KF Kitchen	5/18/2021	Kitchen	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 013A	CR13 CF 28	5/18/2021	Rm 28	Classroom faucet	0.0013	1.3	6/15/2021	OK	
2107235 - 014A	CR14 CF 34 Art	5/18/2021	Rm 34 Art	Classroom faucet	0.0021	2.1	6/15/2021	OK	
2107235 - 015A	CR15 CF 36	5/18/2021	Rm 36	Classroom faucet	0.0022	2.2	6/15/2021	OK	
2107235 - 016A	CR16 WC	5/18/2021	by rm 37	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 017A	CR17 L BF MB	5/18/2021	Men's bathroom rm 35	Left Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 018A	CR18 R BF MB	5/18/2021	Men's bathroom rm 35	Right Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 019A	CR19 L BF WB	5/18/2021	Women's bathroom rm 37	Left Bathroom faucet	0.0018	1.8	6/15/2021	OK	
2107235 - 020A	CR20 R BF WB	5/18/2021	Women's bathroom rm 37	Right Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 021A	CR21 CF 39	5/18/2021	Rm 39	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 022A	CR22 WC 40	5/18/2021	Rm 40	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 023A	CR23 CF SS	5/18/2021	Classroom rm 55	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 024A	CR24 CF	5/18/2021	Classroom rm 55	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 025A	CR25 WC	5/18/2021	by rm 61	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 026A	CR26 BF WB	5/18/2021	Women's bathroom by rm 61	Bathroom faucet	0.0017	1.7	6/15/2021	OK	
2107235 - 027A	CR27 BF MB	5/18/2021	Men's bathroom by rm 61	Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 028A	CR28 KF 75	5/18/2021	Rm 75	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 029A	CR29 KF Storeroom	5/18/2021	Kitchen	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 030A	CR30 L BF MB	5/18/2021	Men's staff bathroom by rm 87	Left Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 031A	CR31 R BF MB	5/18/2021	Men's staff bathroom by rm 87	Right Bathroom faucet	0.0026	2.6	6/15/2021	OK	
2107235 - 032A	CR32 L BF WB	5/18/2021	Women's staff bathroom by rm 87	Left Bathroom faucet	0.0010	1.0	6/15/2021	OK	
2107235 - 033A	CR33 R BF WB	5/18/2021	Women's staff bathroom by rm 87	Right Bathroom faucet	0.0018	1.8	6/15/2021	OK	
2107235 - 034A	CR34 KF 89	5/18/2021	Rm 89	Kitchen faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 035A	CR35 CF 91	5/18/2021	Rm 91	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 036A	CR36 WC	5/18/2021	by boiler room	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 037A	CR37 R BF MB	5/18/2021	Men's bathroom by boiler rm	Right Bathroom faucet	0.0024	2.4	6/15/2021	OK	
2107235 - 038A	CR38 LF BF MB	5/18/2021	Men's bathroom by boiler rm	Left Bathroom faucet	0.0016	1.6	6/15/2021	OK	
2107235 - 039A	CR39 L BF WB	5/18/2021	Women's bathroom by boiler rm	Left Bathroom faucet	0.0015	1.5	6/15/2021	OK	
2107235 - 040A	CR40 R BF WB	5/18/2021	Women's bathroom by boiler rm	Right Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 041A	CR41 WC 103	5/18/2021	Rm 103	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 042A	CR42 KF 103	5/18/2021	Rm 103	Kitchen faucet	0.0021	2.1	6/15/2021	OK	

OCM BOCES - Water Testing for Lead

DOH Action Limit = 15 ppb

date last updated: June 17, 2021

School Name: **Crown Road Campus**

Lab State Certification No: 10248

Method of Analysis: EPA Method 200.8, rev. 5.4/EPA 200.2

Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Test Results mg/liter *	Test Results PPB * <i>(parts per billion)</i>	Lab Report Receipt Date	Current Status	Action Taken
2107235 - 043A	CR43 CF 112	5/18/2021	Rm 112	Classroom faucet	0.0026	2.6	6/15/2021	OK	
2107235 - 044A	CR44 CF 117 Bath	5/18/2021	Rm 117 bathroom	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 045A	CR45 CF 117	5/18/2021	Rm 117	Classroom faucet	0.0016	1.6	6/15/2021	OK	
2107235 - 046A	CR46 KF 122	5/18/2021	Rm 122	Kitchen faucet	0.0023	2.3	6/15/2021	OK	
2107235 - 047A	CR47 CF 117	5/18/2021	Rm 117	Classroom faucet	0.0014	1.4	6/15/2021	OK	
2107235 - 048A	CR48 BF 117	5/18/2021	Rm 117	Bathroom faucet	<0.0010	<1.4	6/15/2021	OK	
2107235 - 049A	CR49 CF 123	5/18/2021	Rm 123	Classroom faucet	0.0035	3.5	6/15/2021	OK	
2107235 - 050A	CR50 BF Gym	5/18/2021	Gym	Bathroom faucet	0.0052	5.2	6/15/2021	OK	
2107235 - 051A	CR51 CF 125	5/18/2021	Rm 125	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 052A	CR52 WC	5/18/2021	by rm 129	Water cooler	<0.0010	<1.0	6/15/2021	OK	
2107235 - 053A	CR53 R BF MB	5/18/2021	Men's bathroom by rm 129	Right Bathroom faucet	0.0011	1.1	6/15/2021	OK	
2107235 - 054A	CR54 L BF MB	5/18/2021	Men's bathroom by rm 129	Left Bathroom faucet	0.0020	2.1	6/15/2021	OK	
2107235 - 055A	CR55 L BF WB	5/18/2021	Women's bathroom by rm 129	Left Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 056A	CR56 R BF WB	5/18/2021	Women's bathroom by rm 129	Right Bathroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 057A	CR57 CF 139	5/18/2021	Rm 139	Classroom faucet	0.0017	1.7	6/15/2021	OK	
2107235 - 058A	CR58 CF 138	5/18/2021	Rm 138	Classroom faucet	<0.0010	<1.0	6/15/2021	OK	
2107235 - 059A	CR59 BF 138	5/18/2021	Rm 138	Bathroom faucet	0.0095	9.5	6/15/2021	OK	
2107235 - 060A	CR60 CF 138	5/18/2021	Rm 138	Classroom faucet	0.0014	1.4	6/15/2021	OK	
2107235 - 061A	CR61 CF 144	5/18/2021	Rm 144	Classroom faucet	0.0012	1.2	6/15/2021	OK	